



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



APR 21 2015

Mr. Shamim Reza
Linn Operating, Inc.
5201 Truxtun Ave, Suite 100
Bakersfield, CA 93309

Re: Notice of Minor Title V Permit Modification
District Facility # S-1246
Project # S-1143238

Dear Mr. Reza:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued Authorities to Construct S-1246-177-10 and '-377-0 (under project S-1124303) into the Title V operating permit. These ATCs authorized the installation of a new 85.0 MMBtu/hr gas-fired steam generator (S-1246-377-0) and allowed the steam generator to combust produced gas from TEOR operation S-1246-177.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued Authorities to Construct S-1246-177-10 and '-377-0, emission increases, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

TITLE V APPLICATION REVIEW

Minor Modification

Project #: S1246, 1143238

Engineer: Steve Davidson

Date: April 10, 2015

Facility Number: S-1246

Facility Name: Linn Operating, Inc

Mailing Address: 5201 Truxtun Ave, Suite 100
Bakersfield, CA 93309

Reviewed by AP SWR AOE
APR 14 2015

Contact Name: Shamim Reza

Phone: (661) 616-3889

Responsible Official: Robert Boston

Title: Manager of EHS

I. PROPOSAL

Linn Operating, Inc is proposing a Title V minor permit modification to incorporate Authority to Construct (ATC) #S-1246-177-10 and '-377-0 into Linn's Title V permit. These ATsC authorized the installation of a new 85.0 MMBtu/hr gas-fired (natural and ethane-rich natural gas) steam generator (S-1246-377-0) and allow the steam generator to combust produced gas from TEOR operation S-1246-177 at the Main Camp Lease in the North Midway Sunset Oilfield (SE/4 of Section: 24, Township: 31S, Range: 22E).

Conditions will be placed on the permit to ensure the units make the requirements of District Rules.

II. FACILITY LOCATION

The equipment is located in the main Camp Lease in the North Midway Sunset Oilfield (SE/4 of Section: 24, Township: 31S, Range: 22E, within Linn's Heavy Oil Western stationary source.

III. EQUIPMENT DESCRIPTION

PTO S-1246-177-10: THERMALLY ENHANCED OIL RECOVERY (TEOR)
OPERATION WELL VENT VAPOR CONTROL SYSTEM
SERVING 75 WELLS INCLUDING GAS/LIQUID SEPARATORS,

GAS COMPRESSOR, AIR-COOLED VAPOR CONDENSER,
VESSELS, SULFUR SCRUBBER AND VAPOR PIPING TO
STEAM GENERATOR '346 and '-377

PTO S-1246-377-0: 85 MMBTU/HR NATURAL/TEOR/ETHANE-RICH NATURAL
GAS-FIRED STEAM GENERATOR (MNJ-402) WITH A NORTH
AMERICAN MAGNA FLAME LE ULTRA LOW NOX BURNER,
FLUE GAS RECIRCULATION (FGR) AND AN O2
CONTROLLER

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to the Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

Authority to Construct (ATC) permit S-1246-177-10 allowed vapors from the TEOR operation to be combusted in steam generator S-1246-377-0. The ATC conditions will be carried over to the proposed PTO with the following exceptions which will be removed:

- The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Y
- Authorities to Construct (ATC) S-1246-177-9 and S-1246-377-0 shall be implemented prior to or concurrently with this ATC. [District Rule 2201] Y [District Rule 2201] Y

ATC S-1246-377-0 is a new permit unit; therefore, there is no existing Title V PTOs that it will be modifying. The ATC conditions will be carried over to the proposed PTO with the following exceptions which will be removed:

- The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Y
- ATC S-1246-177-10 shall be implemented prior to or concurrent with this ATC [District Rule 2201] Y

- Permit S-1246-130 shall be surrendered prior to or concurrent with this ATC.
[District Rule 2201] Y

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include;
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

Because these permit revisions meet all the above criteria, this is a Minor Modification.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

VIII. ATTACHMENTS

- A. Proposed Modified Title V Operating Permit
- B. Authorities to Construct
- C. Emissions Increases
- D. Application
- E. Previous Title V Operating Permit

ATTACHMENT A

Proposed Modified Title V Operating Permit #
S-1246-177-13 and '-377-1

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1246-177-13

EXPIRATION DATE: 03/31/2016

SECTION: 24 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY (TEOR) OPERATION WELL VENT VAPOR CONTROL SYSTEM SERVING 75 WELLS INCLUDING GAS/LIQUID SEPARATORS, GAS COMPRESSOR, AIR-COOLED VAPOR CONDENSER, VESSELS, SULFUR SCRUBBER AND VAPOR PIPING TO STEAM GENERATORS '346 AND '347

PERMIT UNIT REQUIREMENTS

1. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
2. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
3. Fugitive VOC emissions rate for the TEOR operation, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) and the total number of components in gas/light liquid service, shall not exceed 62.1 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0. [District Rule 4401] Federally Enforceable Through Title V Permit
6. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
7. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
8. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
10. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
11. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401] Federally Enforceable Through Title V Permit
12. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401] Federally Enforceable Through Title V Permit
13. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401] Federally Enforceable Through Title V Permit
14. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
15. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
16. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401] Federally Enforceable Through Title V Permit
17. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401] Federally Enforceable Through Title V Permit
18. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401] Federally Enforceable Through Title V Permit
19. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401] Federally Enforceable Through Title V Permit
21. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401] Federally Enforceable Through Title V Permit
22. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401] Federally Enforceable Through Title V Permit
23. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401] Federally Enforceable Through Title V Permit
24. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
25. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
26. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401] Federally Enforceable Through Title V Permit
27. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401] Federally Enforceable Through Title V Permit
28. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
29. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
30. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401] Federally Enforceable Through Title V Permit
31. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
32. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401] Federally Enforceable Through Title V Permit
33. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401] Federally Enforceable Through Title V Permit
35. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401] Federally Enforceable Through Title V Permit
36. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401] Federally Enforceable Through Title V Permit
37. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401] Federally Enforceable Through Title V Permit
38. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401] Federally Enforceable Through Title V Permit
39. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401] Federally Enforceable Through Title V Permit
40. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

41. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401] Federally Enforceable Through Title V Permit
42. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
43. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401] Federally Enforceable Through Title V Permit
44. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401] Federally Enforceable Through Title V Permit
45. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), formerly District Rule 465.1, excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
46. {1769} The crude oil production wells associated with this unit do not have production enhanced by in-situ combustion. Therefore, the requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1246-377-1

EXPIRATION DATE: 03/31/2016

SECTION: SE 24 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

85 MMBTU U/HR NATURAL/TEOR/ETHANE-RICH NATURAL GAS-FIRED STEAM GENERATOR (MCJ-402) WITH A NORTH AMERICAN MAGNA FLAME LE ULTRA LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) AND AN O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. {1829} The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. Unit is authorized to operate at NW Section 2, SW Section 3, and SE Section 3, T31S, R22E. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This unit shall be equipped with horizontal convection section with at least 235 square feet of bare tube surface area (or thermodynamically equivalent number of square feet of finned tube) per MMBtu/hr of heat input. [Public Resources Code 21000-21177: California Environmental Quality Act]
5. This unit shall be equipped with variable frequency drive high efficiency electrical motors driving the blower and water pump. [Public Resources Code 21000-21177: California Environmental Quality Act]
6. The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
9. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
10. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
11. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. This unit shall be fired on natural gas treated to remove 95% by weight of sulfur compounds or treated such that the sulfur content does not exceed 1 gr of sulfur compounds (as S) per 100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
13. The maximum fuel sulfur content shall not exceed 1.75 gr S/100scf. [District Rule 2201] Federally Enforceable Through Title V Permit
14. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
15. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 7 ppmvd NO_x @ 3% O₂ or 0.0085 lb-NO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, 35 ppmvd CO @ 3% O₂ or 0.026 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

27. Permittee shall determine sulfur content of combusted gas weekly for eight consecutive weeks. After demonstrating compliance for eight consecutive weeks testing may be conducted on a quarterly basis. Weekly sulfur testing shall resume if quarterly testing does not indicate compliance. Weekly gas analysis shall be performed using Draeger tubes and quarterly analysis using ASTM method D3246 or double GC for H₂S and mercaptans. First of the weekly gas analyses shall be done using laboratory analysis. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
28. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
29. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. Permittee shall maintain monthly records of gas combusted in this unit. [District Rule 2201] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT B

Authorities to Construct #
S-1246-177-10 and '-377-0



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1246-177-10

ISSUANCE DATE: 02/01/2013

LEGAL OWNER OR OPERATOR: BERRY PETROLEUM COMPANY
MAILING ADDRESS: 5201 TRUXTUN AVENUE SUITE 100
ATTN: EH&S MANAGER
BAKERSFIELD, CA 93309-0422

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: 24 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

MODIFICATION OF THERMALLY ENHANCED OIL RECOVERY (TEOR) OPERATION WELL VENT VAPOR CONTROL SYSTEM SERVING 75 WELLS INCLUDING GAS/LIQUID SEPARATORS, GAS COMPRESSOR, AIR-COOLED VAPOR CONDENSER, VESSELS, SULFUR SCRUBBER AND VAPOR PIPING TO STEAM GENERATOR '346: ALLOW VAPORS TO BE SENT TO STEAM GENERATOR S-1246-377

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
4. Fugitive VOC emissions rate for the TEOR operation, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) and the total number of components in gas/light liquid service, shall not exceed 62.1 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1246-177-10 : Feb 1 2013 10:32AM - DAVIDSOS : Joint Inspection NOT Required

6. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0. [District Rule 4401] Federally Enforceable Through Title V Permit
7. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
8. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
9. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401] Federally Enforceable Through Title V Permit
10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
11. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
12. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401] Federally Enforceable Through Title V Permit
13. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401] Federally Enforceable Through Title V Permit
14. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401] Federally Enforceable Through Title V Permit
15. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
16. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

17. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401] Federally Enforceable Through Title V Permit
18. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401] Federally Enforceable Through Title V Permit
19. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401] Federally Enforceable Through Title V Permit
20. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401] Federally Enforceable Through Title V Permit
21. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401] Federally Enforceable Through Title V Permit
22. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401] Federally Enforceable Through Title V Permit
23. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401] Federally Enforceable Through Title V Permit
24. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401] Federally Enforceable Through Title V Permit
25. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
26. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
27. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401] Federally Enforceable Through Title V Permit
28. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401] Federally Enforceable Through Title V Permit
29. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
31. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401] Federally Enforceable Through Title V Permit
32. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
33. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401] Federally Enforceable Through Title V Permit
34. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401] Federally Enforceable Through Title V Permit
35. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401] Federally Enforceable Through Title V Permit
36. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401] Federally Enforceable Through Title V Permit
37. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401] Federally Enforceable Through Title V Permit
38. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401] Federally Enforceable Through Title V Permit
39. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401] Federally Enforceable Through Title V Permit
40. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

41. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401] Federally Enforceable Through Title V Permit
42. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401] Federally Enforceable Through Title V Permit
43. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
44. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401] Federally Enforceable Through Title V Permit
45. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401] Federally Enforceable Through Title V Permit
46. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), formerly District Rule 465.1, excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
47. The crude oil production wells associated with this unit do not have production enhanced by in-situ combustion. Therefore, the requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
48. Authorities to Construct (ATC) S-1246-177-9 and S-1246-377-0 shall be implemented prior to or concurrently with this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT



HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1246-377-0

ISSUANCE DATE: 02/01/2013

LEGAL OWNER OR OPERATOR: BERRY PETROLEUM COMPANY
MAILING ADDRESS: 5201 TRUXTUN AVENUE SUITE 100
ATTN: EH&S MANAGER
BAKERSFIELD, CA 93309-0422

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: SE 24 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL/TEOR/ETHANE-RICH NATURAL GAS-FIRED STEAM GENERATOR (MNJ-402) WITH A NORTH AMERICAN MAGNA FLAME LE ULTRA LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) AND AN O2 CONTROLLER

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. Unit is authorized to operate at NW Section 2, SW Section 3, and SE Section 3, T31S, R22E. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This unit shall be equipped with horizontal convection section with at least 235 square feet of bare tube surface area (or thermodynamically equivalent number of square feet of finned tube) per MMBtu/hr of heat input. [Public Resources Code 21000-21177: California Environmental Quality Act]
5. This unit shall be equipped with variable frequency drive high efficiency electrical motors driving the blower and water pump. [Public Resources Code 21000-21177: California Environmental Quality Act]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1246-377-0 : Feb 1 2013 10:32AM - DAVIDSOS : Joint Inspection NOT Required

6. The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
9. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
10. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
11. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
12. This unit shall be fired on natural gas treated to remove 95% by weight of sulfur compounds or treated such that the sulfur content does not exceed 1 gr of sulfur compounds (as S) per 100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
13. The maximum fuel sulfur content shall not exceed 1.75 gr S/100scf. [District Rule 2201] Federally Enforceable Through Title V Permit
14. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
15. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 7 ppmvd NO_x @ 3% O₂ or 0.0085 lb-NO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, 35 ppmvd CO @ 3% O₂ or 0.026 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
27. Permittee shall determine sulfur content of combusted gas weekly for eight consecutive weeks. After demonstrating compliance for eight consecutive weeks testing may be conducted on a quarterly basis. Weekly sulfur testing shall resume if quarterly testing does not indicate compliance. Weekly gas analysis shall be performed using Draeger tubes and quarterly analysis using ASTM method D3246 or double GC for H₂S and mercaptans. First of the weekly gas analyses shall be done using laboratory analysis. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
28. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
29. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. Permittee shall maintain monthly records of gas combusted in this unit. [District Rule 2201] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
35. Prior to operating equipment under this Authority to Construct, permittee shall surrender emission reduction credits for the following quantities of emissions: NO_x: 2234 lb/quarter; SO_x: 1396 lb/quarter; PM₁₀: 1396 lb/quarter and VOC: 1536. Offsets include the applicable offset ratio specified in Section 4.8 of Rule 2201 (as amended 4/21/11). PM₁₀ may be offset using SO_x at an interpollutant offset ratio of 1.0 tons SO_x/ton PM₁₀. [District Rule 2201] Federally Enforceable Through Title V Permit
36. ERC Certificate Numbers S-3970-2, S-3879-5, and N-1074-1 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
37. ATC S-1246-177-10 shall be implemented prior to or concurrent with this ATC [District Rule 2201] Federally Enforceable Through Title V Permit

ATTACHMENT C

Emissions Increases

	SSIPE (lb/yr)				
	NOx	VOC	CO	SOx	PM10
#S-1246-177-10	0	0	0	0	0
#S-1246-0377-0	5957	26,722	19,360	3723	3723
Total	0	621	0	0	0

ATTACHMENT D

Application

San Joaquin Valley Air Pollution Control District

www.valleyair.org


RECEIVED

JUL 24 2014

SJVAPCD
Southern Region

Permit Application For:

[X] ADMINISTRATIVE AMENDMENT [] MINOR MODIFICATION [] SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: Berry Petroleum Company, LLC	
2. MAILING ADDRESS: <div style="text-align: center;">5201 Truxtun Ave., Suite 100</div> <div style="display: flex; justify-content: space-between;"> <div>STREET/P.O. BOX:</div> <div>CITY: Bakersfield STATE: CA 9-DIGIT ZIP CODE: 93309</div> </div>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: <div style="display: flex; justify-content: space-between;"> <div>STREET: Main Camp</div> <div>CITY: _____</div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div>_____ ¼ SECTION</div> <div>TOWNSHIP _____</div> <div>RANGE _____</div> </div>	INSTALLATION DATE: _____
4. GENERAL NATURE OF BUSINESS: Oil and gas production	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary) Implement 2 Authorities to Construct for a TEOR operation and 1 steam generator S-1246-177-10, and '-377-0.	
6. TYPE OR PRINT NAME OF APPLICANT: Shamim Reza	TITLE OF APPLICANT: Environmental Specialist
7. SIGNATURE OF APPLICANT: <div style="text-align: center;">  </div>	<div style="display: flex; justify-content: space-between;"> <div>DATE: 7/24/14</div> <div>PHONE: (661) 616-3889</div> </div> <div style="display: flex; justify-content: space-between;"> <div></div> <div>FAX: _____</div> </div> <div style="display: flex; justify-content: space-between;"> <div></div> <div>EMAIL: sreza@linenergy.com</div> </div>

For APCD Use Only:

DATE STAMP	FILING FEE RECEIVED: \$ _____ CHECK#: _____ DATE PAID: _____ PROJECT NO: S-1143238 FACILITY ID: S-1246
------------	--

**San Joaquin Valley
Unified Air Pollution Control District**

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

☐ SIGNIFICANT PERMIT MODIFICATION
☐ MINOR PERMIT MODIFICATION

☒ ADMINISTRATIVE
AMENDMENT

COMPANY NAME: Berry Petroleum Company, LLC.	FACILITY ID: S-1246
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: Berry Petroleum Company, LLC.	
3. Agent to the Owner: Tim Crawford	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):


☒ Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).

☒ Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.

☒ Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.

☒ Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:



Signature of Responsible Official

7/24/14

Date

Robert Boston

Name of Responsible Official (please print)

Manager of EHS

Title of Responsible Official (please print)



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1246-377-0

ISSUANCE DATE: 02/01/2013

LEGAL OWNER OR OPERATOR: BERRY PETROLEUM COMPANY
MAILING ADDRESS: 5201 TRUXTUN AVENUE SUITE 100
ATTN: EH&S MANAGER
BAKERSFIELD, CA 93309-0422

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: SE 24 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL/TEOR/ETHANE-RICH NATURAL GAS-FIRED STEAM GENERATOR (MCJ-402) WITH A NORTH AMERICAN MAGNA FLAME LE ULTRA LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) AND AN O2 CONTROLLER

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. Unit is authorized to operate at NW Section 2, SW Section 3, and SE Section 3, T31S, R22E. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This unit shall be equipped with horizontal convection section with at least 235 square feet of bare tube surface area (or thermodynamically equivalent number of square feet of finned tube) per MMBtu/hr of heat input. [Public Resources Code 21000-21177: California Environmental Quality Act]
5. This unit shall be equipped with variable frequency drive high efficiency electrical motors driving the blower and water pump. [Public Resources Code 21000-21177: California Environmental Quality Act]

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST** NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Sayed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1246-377-0; Aug 16 2013 4:18PM - ROEDERS : Joint Inspection NOT Required

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308 • (661) 392-5500 • Fax (661) 392-5585



5201 Truxtun Ave.
Bakersfield, California 93309

Phone: (661) 616-3900

RECEIVED
JUL 24 2014
SJVAPCD
Southern Region

July 22, 2014

Mr. Leonard Scandura
San Joaquin Valley Unified APCD
34946 Flyover Court
Bakersfield, CA 93308

RE: Title V Modification – a TEOR operation and one steam generators

Dear Mr. Scandura:

Berry Petroleum Company, LLC/Linn Energy is implementing 2 Authorities to Construct (ATC) for a TEOR operation (S-1246-177-10) and one steam generator S-1246-377-0 at BPC's Midway Sunset Oilfield, Kern County Heavy Oil Western Stationary Source. Enclosed for your review please find the following:

- Application for Title V Modification (TVFORM-008)
- Title V Compliance Certification (TVFORM-009)
- Copy of the first page for the referenced ATCs

If you should have any questions or require additional information please contact me at (661) 616-3889 or by e-mail at sreza@linenergy.com.

Sincerely,

Shamim Reza
Environmental Specialist

Enclosures

ATTACHMENT E

Previous Title V Operating Permit
S-1246-177-10 and '-377-0

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1246-177-11

EXPIRATION DATE: 03/31/2016

SECTION: 24 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY (TEOR) OPERATION WELL VENT VAPOR CONTROL SYSTEM SERVING 75 WELLS INCLUDING GAS/LIQUID SEPARATORS, GAS COMPRESSOR, AIR-COOLED VAPOR CONDENSER, VESSELS, SULFUR SCRUBBER AND VAPOR PIPING TO STEAM GENERATOR '346

PERMIT UNIT REQUIREMENTS

1. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
2. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
3. Fugitive VOC emissions rate for the TEOR operation, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) and the total number of components in gas/light liquid service, shall not exceed 62.1 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0. [District Rule 4401] Federally Enforceable Through Title V Permit
6. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
7. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
8. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: LINN OPERATING, INC

Location: HEAVY OIL WESTERN STATIONARY SOURCE, KERN COUNTY, CA

S-1246-177-11 : Apr 10 2015 9:44AM - DAVIDSOS

9. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
10. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
11. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401] Federally Enforceable Through Title V Permit
12. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401] Federally Enforceable Through Title V Permit
13. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401] Federally Enforceable Through Title V Permit
14. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
15. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
16. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401] Federally Enforceable Through Title V Permit
17. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401] Federally Enforceable Through Title V Permit
18. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401] Federally Enforceable Through Title V Permit
19. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401] Federally Enforceable Through Title V Permit
21. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401] Federally Enforceable Through Title V Permit
22. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401] Federally Enforceable Through Title V Permit
23. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401] Federally Enforceable Through Title V Permit
24. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
25. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
26. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401] Federally Enforceable Through Title V Permit
27. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401] Federally Enforceable Through Title V Permit
28. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
29. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
30. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401] Federally Enforceable Through Title V Permit
31. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
32. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401] Federally Enforceable Through Title V Permit
33. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401] Federally Enforceable Through Title V Permit
35. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401] Federally Enforceable Through Title V Permit
36. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401] Federally Enforceable Through Title V Permit
37. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401] Federally Enforceable Through Title V Permit
38. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401] Federally Enforceable Through Title V Permit
39. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401] Federally Enforceable Through Title V Permit
40. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

41. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401] Federally Enforceable Through Title V Permit
42. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
43. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401] Federally Enforceable Through Title V Permit
44. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401] Federally Enforceable Through Title V Permit
45. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), formerly District Rule 465.1, excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
46. The crude oil production wells associated with this unit do not have production enhanced by in-situ combustion. Therefore, the requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.